

## CERTIFICATION OF COMPLIANCE

Pentair Water Pool and Spa Inc., 1620 Hawkins Ave., Sanford, NC 27330, (800) 831-7133, hereby certifies that the following model numbers meet or exceed the requirements of Section 1404 of the Virginia Graeme Baker Act Pool & Spa Safety Act, VGB 2008 and ASME/ANSI A112.19.8a (addendum 8a-2008) standards and safety regulations as set forth by the Consumer Products Safety Commission:

CHART 3			
Part No.	Open Area	Flow Rating Floor	Flow Rating Wall
5004XX	38.70 in <sup>2</sup>	270 GPM	270 GPM
5005XX	76.00 in <sup>2</sup>	360 GPM	360 GPM
5006XX	154.80 in <sup>2</sup>	740 GPM	740 GPM
5007XX	304.00 in <sup>2</sup>	1428 GPM	1428 GPM

IAPMO Certified

These products were tested and certified to the aforementioned safety regulations, by IAPMO Research and Testing, 5001 E. Philadelphia St. Ontario, CA 91761 – USA 877-4UPCMARK (toll free)

Product certification commenced April 2009, test results can be obtained from: [www.pentairwater.com](http://www.pentairwater.com) and/or <http://pld.iapmo.org/>

Each product contains a circular date stamp on the top or bottom of the product showing the month and year of manufacture. These products are manufactured at AquaStar® Pool Products, San Diego, California in the United States of America.

A copy of this certificate is available on the Pentair Water Pool and Spa Inc. website: [www.pentairwater.com](http://www.pentairwater.com)

Note to installer/owner:

Enter the information below: Please keep this page as a record of the installation date.

Date of Installation: \_\_\_\_\_